CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1004:101 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Air Products and Controls Inc., 1749 East Highwood, Pontiac, MI 48340

Contact: *Bill Ryan (248) 332-3900

DESIGN: Models MR-101/C, MR-104/C, MR-201/C, MR-201/CX, MR-204/C, MR-204/CX, PAM-1,

> PAM-2, PAM-2X, PAM-3, PAM-4, PAM-SD, RIC-1 and RIC-2 relay modules. Models MR-101/C, -201/C and -201/CX may employ suffix -R or -S. Refer to listee's data sheet for

detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, electrical rating and UL label.

APPROVAL: Listed as relay modules for use with separately listed compatible control units.

*Rev. 11-12-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsementor recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 12, 2002 Date Issued: Listing Expires June 30, 2003

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager